



- NOTE:
1. USE 3000 P.S.I. CONCRETE.
  2. SLAB THICKNESS TO BE 12".
  3. ALL REINFORCING STEEL TO BE 3" BELOW TOP OF PAD.



TYPICAL STEEL REINFORCED  
CONCRETE PAD FOR SINGLE-PHASE  
PAD-MOUNTED TRANSFORMER

DEVELOPED BY:

STANDARDS  
COMMITTEE

APPROVED:

SEP 2020

DRAWING  
NUMBER

UD-14

